

### Emergency Lighting Spacing Table

#### 1 Lux minimum at wall base- Point of emphasis

#### Horizontal Lux levels at wall base, up to 2m from wall - Point of emphasis

Mounting height	Lux level directly beneath	Transverse distance to wall for level of illuminance (1 lux)
2.5m	4.5 lux	3.75
3.0m	3.15 lux	3.8
3.5m	2.6 lux	3.7
4.0m	1.8 lux	3.5

Mounting height	Distance from wall 0.5m	Distance from wall 1.0m	Distance from wall 1.5m	Distance from wall 2.0
2.5m	4.2 lux	3.3 lux	2.4 lux	1.9 lux
3.0m	3.0 lux	2.5 lux	2.0 lux	1.6 lux
3.5m	2.2 lux	1.9 lux	1.6 lux	1.3 lux
4.0m	1.7 lux	1.5 lux	1.3 lux	1.1 lux

*Illuminance values based on maintenance factor of 0.9*